

2013-413  
HIDDEN VALLEY SPORTS PARK OSSF  
Questions & Answers  
August 26, 2013

1. Can the tank be backfilled with material excavated  
**Material used for backfill must comply with TAC 285.32(b)(F).**
2. Can Material left over from excavation be spread out on site or will it need to be hauled out.  
**Excess material must be removed from the site.**