



OFFICE OF COUNTY PURCHASING

March 28, 2017

BID 2017-405
SOLMS ROAD, WALD ROAD, AND ALTGELT LANE RESURFACING PROJECT
Q & A

Level up question – Will it cover the entire road or spot level up? <i>It will cover the entire road, matching the existing cross-slope (see typical sections).</i>
Must the level up be bladed laid? <i>Yes, in accordance with TxDOT Specification 3035.</i>
In project notes it is referenced that Level-up will be paid by the ton but there is no ton bid item ? <i>See attached Revised Overlay Bid Form</i>
Does the tonnage for level up (which is referenced to be paid by the tons installed) be included in the If bid item per street, or is this budget separately? <i>See attached Revised Overlay Bid Form</i>
Work hours? <i>No limitation. Please ensure county knows work hours if outside of normal business hours (M-F 0800-1630)</i>
Traffic control – Can the locations be shut down and detour traffic? <i>See Specification 1.6.3.</i>